

Village of Skaneateles
Wastewater Treatment Operations
From: Adam Twitchell
RE: November 2023 Monthly Report

We treated 15.55 Million Gallons of wastewater this month.

The average flow per day was 0.52 MGD

Total rainfall for the month was 2.51 inches

We hauled 40,500 gallons of sludge to the Auburn wastewater treatment plant.

- We did all the monthly maintenance on all of the equipment.
- We passed all of the monthly tests.
- I successfully filled out and submitted the monthly DMR to the DEC.
- Cyclops came and installed new batteries in all the gas detectors throughout the plant. These new batteries are supposed to last longer.
- Cyclops came to the plant to calibrate all of the gas detectors.
- the TRC project is progressing in accordance with the Contract Documents. The Contractor is finishing up submittals and is completing site/misc concrete work while awaiting equipment to arrive. We anticipate the contractor to make significant progress in Q1 2024 once equipment arrives.